



PERMANENT DOCUMENT

**ENEC 303
Annex G**

**Annex G
to Routine Test Requirements for manufacturers
(as per Article 9 of the Agreement)**

**Ballasts for discharge lamps covered by
EN 61347-2-9 (safety) – EN 60923 (performance)**

Approved by:
Date of issue:
Supersedes:

ENEC Group Postal Vote of 6 October 2010
December 2010
PD ENEC 303 Annex G – September 2000

No. of pages: 2
Page 1 of 2

Annex G to PD ENEC 303

Ballasts for discharge lamps covered by EN 61347-2-9 (safety) – EN 60923 (performance)

1 ROUTINE TESTS (100%)

- 1.1 Visual check of marking and workmanship *)
- 1.2 Voltage test applied for a period of 1 second between live parts and the body as indicated in the following table:

Operating voltage	Test voltage
Less than or equal to 42 V	500 V
More than 42 V but less than or equal to 1000 V	$2 U + 1000 \text{ V}$

- 1.3 Check of the rated current or impedance

2 PERIODIC TESTS

- 2.1 Endurance test (at least once every two years)

This test shall be carried out on a sample of each series/family (same basic construction).

- 2.2 Terminals, screws, current-carrying parts and connections (at least once a year)

- 2.3 Protection against accidental contact with live parts and creepage distances and clearances measurement (at least once a year)

*) Workmanship means:

Completeness of product, all parts correctly mounted, without visible defects, no sharp edges which may cause damage or injuries.
