

HAR Agreement	PERMANENT DOCUMENT	PD 10
--------------------------	---------------------------	--------------

HAR threads



Approved by the HAR Group on 19th April 2004

Date of issue : May 2004
This document supersedes
PD 10 issue December 2002

This document contains 3 pages

Page 1 of 3

| new or revised item

IDENTIFICATION THREADS FOR HARMONISED CABLES

Distinction of the countries of origin by different lengths of the colour-code and the colour fields.

The following requirements have to be taken into consideration for the manufacturing of the identification threads:

- (a) the basic colour is yellow;
- (b) the length of the colour fields printed in black and red must be either 1 cm or 3 cm;
- (c) the manufacturer of these threads guarantees a tolerance of about 1-2 mm of the length of the colour fields.

Notes:

- (1) Used by VDE for PVC cables from 1938 to 1975.
- (2) Formerly AEE (Spain).
- (3) Formerly NSAI (Ireland).



